

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0809 - CPR - 1018**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Smoke control damper SCS

of sizes (200 x 200) mm<sup>2</sup> – (1250 x 1000) mm<sup>2</sup>, used for single compartment applications and equipped with electrical Belimo BE actuator and classified as

**E<sub>600</sub> 120 (h<sub>odw</sub>-i↔o) S 1500 C<sub>10000</sub> AAsingle**

**E<sub>600</sub> 120 (h<sub>odw</sub>-i↔o) S 1500 C<sub>10000</sub> MAsingle**

**E<sub>600</sub> 120 (v<sub>ew</sub>-i↔o) S 1500 C<sub>10000</sub> AAsingle**

**E<sub>600</sub> 120 (v<sub>ew</sub>-i↔o) S 1500 C<sub>10000</sub> MAsingle**

produced by

**Halton Oy**

Haltonintie 1-3  
FI-47400 Kausala

and produced in the manufacturing plant

**Halton Oy**

Haltonintie 1-3  
FI-47400 Kausala

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 12101-8:2011**

under system 1 are applied and that

**the construction products fulfil all the prescribed requirements for these performances.**

This certificate was first issued on October 2, 2013, updated latest on September 8, 2015, and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Espoo September 8, 2015

  
Tiina Tirkkonen  
Product Manager

  
Matti Immonen  
Lead Assessor