



PAVUS, a.s.

www.pavus.cz

Notified body 1391, Authorized body AO 216, EGOLF member, Fire testing laboratory
Certification body for products and for quality system certification, Expertises, Inspections

Headquarters:

Prosecká 412/74, 190 00 Praha 9, Czech Republic
tel.: +420 286 019 587; fax: +420 286 019 590; e-mail: mail@pavus.cz

Fire testing laboratory:

Čtvrť J. Hybeše 879, 391 81 Veselí nad Lužnicí, Czech Republic
tel.: +420 381 477 418; fax: +420 381 477 419; e-mail: veseli@pavus.cz

Your ref. / letter: 15th April 2019
Transacted by / contact: Radek Hruška
Our ref. / letter: 195-hr from day 16th April 2019

Halton Oy
Mr. Raimo Parkkila
Haltonintie 1 – 3
47400 KAUSALA
Finland

Subject: Confirmation for fire dampers EDC, ESC, ETC, ESR and ETR

The fire dampers EDC, ESC, ETC, ESR and ETR have been tested according to EN 1366-2 and mounted according to clause 6.3 both within the wall or floor opening and remote from the wall or floor for classification according to EN 13501-3+A1 and for certification according to EN 15650.

Best regards

PAVUS, a.s.
Autorizovaná osoba AO 216
Pobočka
391 81 Veselí nad Lužnicí

Radek HRUŠKA
Technical manager
PAVUS, a.s.,
Fire testing laboratory Veselí nad Lužnicí
Czech Republic