

# DECLARATION OF PERFORMANCE (DoP)

No. 10036-SFR-2019/01/01

1. Unique identification code of the product type:

**Halton Sec Fit Rectangular (SFR)**

**Smoke control damper, fire resistance class:**

**E<sub>600</sub> 90 (v<sub>ed</sub>-i↔o) S1000C<sub>300</sub>AAsingle**

2. Intended use:

**Smoke control dampers that are to be used in smoke control systems in single compartment applications at temperatures up 600°C.**

3. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant Article 11(5):

**Halton Oy  
Haltonintie 1-3  
47400 Kausala  
FINLAND  
Tel. +358 (0)20792 200  
Code: Hal 26724**

4. System of AVCP:

**System 1  
See Regulation (EU) No. 305/2011 (CPR) Annex V, 1.2.**

5. Harmonised standard:

**EN 12101-8:2011**

6. Notified body:

**Notified body No. 1391  
PAVUS, a.s.  
Prosecká 412/74, 19000 Praha 9-Prosek  
CE certificate of Constancy of Performance No: 1391-CPR-2018/0209**

## 7. Declared performance/s of Halton Sec Fit Rectangular (SFR)

Essential characteristics	Requirements of EN 12101-8	Findings <sup>1)</sup>	Conformity Assessment
Nominal activation conditions/sensitivity	4.2.1.3	Comply with EN 12101-8, 4.2.1.3	Conforms
Response delay (response time)	4.2.1.4	< 60 s, according to EN 12101-8, 4.2.1.4	Conforms
Operational reliability	4.3.2.2	C 10 000	Conforms
<b>Fire resistance</b>			
- Integrity (E)	4.1.1, a), 4.3.1	E < 360 m <sup>3</sup> / (h.m <sup>2</sup> )	Conforms
- Insulation (EI)	-	- <sup>2)</sup>	NPD
- Smoke leakage (ES)	4.1.1, c), 4.3.1	S < 200 m <sup>3</sup> / (h.m <sup>2</sup> )	Conforms
- Mechanical stability (under E)	4.1.1, d)	E – requirements fulfilled	Conforms
- Maintenance of the cross section (under E)	4.1.1, e)	E – requirements fulfilled	Conforms
- High operational temperature	4.1.1, f), 4.3.1	-	NPD
<b>Durability</b>			
- of response delay	4.3.2.1	< 60 s	Conforms
- of operational reliability	4.3.2.2	C 300, response time < 120 s	Conforms

<sup>1)</sup> Detailed technical parameters, fire classification and conditions of final classification according to EN 13501-4:2016 are stated in the certification report no: P-1391-CPR-2018/0209 of 29<sup>th</sup> October 2018.

<sup>2)</sup> For single compartment smoke control dampers it is not required/declared.

8. The performance of the product identified in point 1 is in conformity with the set of declared performance/s.

This declaration of performance is issued in accordance with Regulation (EU) No 305/2011 (CPR), under the sole responsibility of the manufacturer identified in point 3.

Copy of Declaration of Performance (DoP) for Halton Sec Fit Rectangular (SFR) is available on website:

[www.halton.com](http://www.halton.com)

Signed for and on behalf of the manufacturer by:

Raimo Parkkila – Manager, System and Product Development

Kausala, 1<sup>st</sup> of January 2019

