



Transport
Canada
Safety and Security

 Page
 1 of 4

 Certificate No:
 LR2018415TC

 Issue Date:
 18/03/2020

 Expiry Date:
 17/03/2025

# Certificate Of Type Approval Issued On Behalf Of Transport of Canada

This is to certify that the product detailed below will be accepted for compliance with the applicable Lloyd's Register Rules and Regulations and with the International Convention for the Safety of Life at Sea, (SOLAS), 1974, as amended, for use on ships and offshore installations classed with Lloyd's Register, and for use on ships and offshore installations when authorised by Transport Canada to issue the relevant certificates, licences, permits etc.

Address Pulttikatu 2, 15700 Lahti, Finland

**Type** Fire Damper (Standard Fire Test)

**Description** Single or Multi-bladed Rectangular Fire Dampers – Types: "FDB2-EL, FDB2-PNR"

**Trade Name** FDB2-EL, FDB2-PNR

**Specified Standard** IMO Res. MSC.61 (67) - (FTP Code) Annex 1, Part 3

IMO MSC/Circ.1120

IMORes. MSC.307(88) - (2010 FTP Code) Section 8

This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document and its supplementary Type Approval Terms and Conditions form part of this Certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached Design Appraisal Document are complied with and the equipment remains satisfactory in service.

**Keith Taylor** 

Team Lead Fire & Safety to Lloyd's Register EMEA

A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 4

Certificate No: LR2018415TC Issue Date: 18/03/2020

Expiry Date: 17/03/2025

Reference: UKITSO/FIRE/TA/KT/WP40375317

### ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. LR2018415TC

The undernoted documents have been appraised for compliance with the relevant requirements of International Conventions, and this Design Appraisal Document forms part of the Certificate.

# **APPROVAL DOCUMENTATION**

- VTT Technical Research Centre of Finland, Espoo, Finland, Test Report No's: RTE 1133/05 and RTE 1134/05, both dated 24 May 2005; VTT-S-10161-07, dated 23 November 2007; VTT-S-7445-10 and VTT-S-7447-10, dated 27 September 2010; VTT-S-08754-13 and VTT-S-07638-13, both dated 07 January 2014.
- 2. VTT Statement No VTT-S-3913-09 for thickness casing more than 5 mm up to 10 mm, dated 16 June 2009.
- 3. VTT Statement No. VTT-S-3542-10 for joining single units in a multiple unit assembly, dated 28 April 2010.

# **CONDITIONS OF CERTIFICATION**

- 1. For use in A-0 Class divisions with fire damper insulated and in A-15, A-30 and A-60 Class divisions with both the ducting and fire damper suitably insulated in accordance with Condition 9 below.
- 2. Minimum and maximum size of damper: 100mm x 100mm up to 2000mm x 1900mm (mullion arrangement)
- 3. Single or Multi-bladed fire dampers 210mm deep with outer casing composed of at least 3mm thick stainless steel or galvanised steel. Blades are composed of stainless or galvanized steel 1mm, with a double skin hollow profile of total thickness 20mm.
- 4. Fire dampers are bolted to the coamings with M10 bolts spaced at 150 mm intervals.
- 5. The fire dampers are fitted with Pyrocryl gasket seals (intumescent based gasket seal) between the fire damper and the coaming which may emit smoke and toxic gases at elevated temperatures, therefore they are restricted for use in ducts serving unmanned spaces only. The use of such dampers in ducts serving manned spaces, defined as spaces where people normally work or live, must be separately approved at the design stage by the Plan Approval authority for each project.
- 6. The dampers are fitted with either:
  - a. (FDB2-EL) Schischek: 15F, ExMAX-15-SF, RedMAX-15-SF, ExMAX-5.10-SF
  - b. (FDB2-EL) Belimo: SF24 ALON, SR 24/120/230
  - c. (FDB2-EL) Siemens: GGA 326.1 E & GGA 126 electric actuators
  - d. (FDB2-PNR) Air Torque AT100 S10 B
  - e. (FDB2-EL) Elodrive CSQP 15A1E electric actuator
  - f. (FDB2-EL) Belimo SF24A-SR-S2 electric actuator, for applications in steel decks only
  - g. (FDB2-EL) Schischek ExMax-5.10-YF electric actuator, for applications in steel decks only
- 7. Actuators and corresponding thermal triggers/fusible link mechanisms are restricted for use with up to the maximum size damper tested and in the tested orientation (bulkheads/decks). Actuators fire tested with the smaller dampers and identified on this Certificate may be accepted with larger dampers on a case-by-case basis, subject to satisfactory test evidence provided to the final Project Plan Approval Authority to demonstrate they are able to close the larger damper at least within the same time period as in the actual fire tests. Factory tests performed under Lloyd's Register witness in ambient temperature conditions with 5 seconds applied as a compensation factor (due to factory testing conducted,

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

IS IS

IS IS

<u>R</u>

R

LR

R D

R

R

 $\frac{\mathbb{R}}{\mathbb{R}}$ 

R



 Page
 3 of 4

 Certificate No:
 LR2018415TC

 Issue Date:
 18/03/2020

Expiry Date: 17/03/2025

UKITSO/FIRE/TA/KT/WP40375317

# ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. LR2018415TC

not under fire conditions) may also be accepted as suitable test evidence; for example, if the closure time for larger damper in the fire test is 30 seconds, actuator tested with smaller dampers must be able to close the larger damper at least within 25 seconds in the factory test.

Reference:

- 8. Derivations of fire tested actuators, outlined in Condition 6 above, such as in different voltage supplies, different electric connection specifications (European/American etc.) and with higher performance ratings such as IP Ratings, Explosive Ratings etc. may be accepted on a case-by-case basis, subject to formal confirmation from the actuator manufacturer provided to the final project authorities that such changes do not adversely affect their functionality and performance or reduce damper closure times. Tested actuators in alternative material options cannot be accepted under this Certificate.
- 9. Table of Insulation Requirements for Decks and Bulkheads (insulated length may be interpolated from the results shown below using the cross-sectional area of fire damper). Insulation on duct to be the same fire rating as that used on the division, but insulation on fire damper in all cases to be A-60 Class. For single fire dampers joined together in a multiple unit assembly each fire damper to be insulated separately as shown in the below table.

Cross-Sectional Area of Fire Damper (mm)	Total Insulated length (mm) including fire damper	Fire Damper Unit Type
100 x 100	900	Single
1600 x 1200	1400	Single
2000 x 1900	1900	Double with mullion

- 10. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.
- 11. All instructions or markings that accompany life-saving appliances or are printed directly on the appliances must be in both English and French, as per Canadian procedures for approval of life-saving appliances and fire safety systems, equipment and products document no. TP 14612E (05/2011) paragraph 2.2.1.3. However independent signage can be accepted in lieu of the instructions or marking required in paragraph 2.2.1.3 if it is in both English and French, highly visible (size, colour, posting location), water and weather proof and posted at each muster station and where the appliance is stored.
- 12. The Certificate holder is solely responsible for the products supplied under this Certificate and to ensure that their products, whether manufactured by themselves or their licensee manufacturers, if agreed by Lloyd's Register, are fully compliant with the relevant statutory regulations and Lloyd's Register Class Rules as applicable and designed, manufactured and installed to the same quality and specifications as the prototype tested, including components that are designed and manufactured by third parties.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 4 of 4

Certificate No: LR2018415TC Issue Date: 18/03/2020

Expiry Date: 18/03/2020

Reference: UKITSO/FIRE/TA/KT/WP40375317

### ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. LR2018415TC

# **PLACE OF PRODUCTION**

Halton Marine Oy Pulttikatu 2 FI-15700 Lahti Finland Halton Ventilation (Shanghai) Co. Ltd. Block 10, 600 Xinyuan Road Lingang New City, Pudong Shanghai, 201306 People's Republic of China

Keith Teyler

Keith Taylor Team Lead, Fire & Safety Statutory Discipline Team UK&I Technical Support Office, Marine & Offshore Lloyd's Register

# Supplementary Type Approval Terms and Conditions

This Certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.